MONMOUTH COUNTY HEALTH DEPARTMENT
3000 KOZLOSKI RD.
FREEHOLD, NJ 07728
TEL: (732) 431-7456 FAX (732) 409-7579

N.J.A.C. 8:26 PUBLIC RECREATIONAL BATHING

DATE: 11/24/2026

PRE-OPERATIONAL INSPECTION ☐
ROUTINE INSPECTION ☑
RE-INSPECTION ☐

SATISFACTORY ☐
CONDITIONAL ☐
UNSATISFACTORY ☑

FA [redacted] 400 Cedar Avenue

MUNICIPALITY West Long Branch

Tel (732) 571-3425

L ☐ YEAR-ROUND ☑

OUTDOOR ☐ INDOOR ☑

SPECIALLY EXEMPT YES ☐ NO ☑ VC ☐

Lab E. Runyon

TP [redacted]

SAMPLING AND WATER QUALITY

IN	OUT	
☑	☐	TPO visits once per week, documented and available
☑	☐	Written SOP Aquatics Facility Plan available/ complete
☑	☐	Bound log maintained (chemical)
☑	☐	Monitor for Chlorine/ Bromine residual and pH value
☑	☐	Manually every 2 hours or x2 daily Chemical control system
☑	☐	Chemical controller system sensors accurate
☑	☐	ORP chart readily available onsite
☑	☐	Pool water clarity adequate
☑	☐	Chlorine/Bromine Residual: 1.5 pH Value: 6.8

CONSTRUCTION AND DESIGN

IN	OUT	
☑	☐	Municipal electrical inspection date: 9/29/2026
☐	☒	Bonding & grounding certification| Exp. date: 11/2/2026
☑	☐	Virginia Graeme Baker Act compliant | Exp. date: 11/22/27
☑	☐	Suction outlet & main drain covers present, attached, sound
☑	☐	Fencing conforms w/NJUCC; 4' barrier around wading pool
☑	☐	Surfaces smooth, safe; facility maintained, safe, hazard free
☑	☐	Pump suction gauge, filter in/outlet pressure gauges present
☑	☐	Flow meter(s) present

SIGNAGE

IN	OUT	
☑	☐	Bather Rules conspicuously posted, verbatim (11)
☑	☐	Diving rules conspicuously posted, words and pictures
☑	☐	Name and telephone of designated adult supervisor
☑	☐	Depth markings on vertical wall and top coping or edge of deck
☑	☐	Emergency telephone numbers (rescue squad, police)
☑	☐	Address of pool posted near emergency telephone
☑	☐	Location of first aid supplies posted
☑	☐	MCHD inspection placard posted near the public entrance
		Specially Exempt *Not Applicable* ☑
☐	☐	Proper signage verbatim at every entrance (registration/ rooms)
		Hot Tub *Not Applicable* ☑
☐	☐	Proper signage verbatim
☐	☐	Pump shut off prominently marked and accessible
		Wading Pools / Spray Parks *Not Applicable* ☑
☐	☐	Proper signage verbatim

LIFEGUARD NAME Ziv Cohen

CERTIFICATION ARC

EXP. DATE 4/16/28

INSPECTOR NAME Muscillo, Lisa Digitally signed by Muscillo, Lisa Date: 2026.11.24 12:33:10 -05'00'

EMERGENCY EQUIPMENT

IN	OUT	
☑	☐	One or more assist poles or hooks non-telescoping
☑	☐	One or more rescue tubes for each lifeguard
☐	☐	One or more rings or buoy (exempt facilities)
☑	☐	First Aid kit
☑	☐	Full Spine board with straps; poolside
☑	☐	Telephone or approved means of communication
☑	☐	One or more throw lines
☑	☐	AED in plain sight easily accessible if lifeguard present
		Hot Tubs/ Spas *Not Applicable* ☑
☐	☐	Water temperature (Max 104°F) automatic shut off installed
☐	☐	Thermometer provided
☐	☐	Clock provided and visible from hot tub or spa

SPRAY PARKS, WADING POOLS & AQUATIC PLAY EQUIPMENT

		Spray Parks & Wading Pools *Not Applicable* ☑
☐	☐	Individual supervisor
☐	☐	First aid, CPR certified individual accessible
		Water Slides *Not Applicable* ☑
☐	☐	Lifeguard supervision with clear view and access to slide
☐	☐	Slide area and landing area clearly delineated
		Rope Drops, Cliff Jumps, Floats & Fixed Platforms *N/A* ☑
☐	☐	Approved and in compliance with N.J.A.C 8:26

GENERAL SANITATION & MAINTENANCE

IN	OUT	
☑	☐	Facility clean, sanitary, safe condition
☑	☐	Dressing rooms, bathrooms provided; adequate; equipped

Remarks

Acting Aquatics Director: Hayley Masi

AED Pads expire 10/28/2028

Emergency telephone tested and operating correctly.
Emergency pump shut off tested and operating correctly.

Bonding & Grounding certification expired on 11/2/2026.
New updated Bonding & Grounding certification not available.

*****Pool is CLOSED and must stay closed until a current Bonding & Grounding certificate is provided and approval is given by the Health Department to reopen.

RECEIVED BY